



NOTES:

1. KEEP FOUNDATION SEALER A MINIMUM OF 12" FROM OPENING.
2. POUR A MINIMUM OF A 11½" STEP IN BULKHEAD OPENING AS SHOWN.
3. KEEP A MINIMUM OF 18" FROM FOUNDATION CORNER.
4. ROOF DRAINAGE SHOULD BE DIVERTED AWAY FROM BULKHEAD OPENING.
5. PERIMETER DRAINAGE RECOMMENDED.
6. BACK FILL SHOULD BE CLEAN GRAVEL WELL COMPACTED.
7. HOW TO ORDER:
 DETERMINE DIMENSION FROM TOP OF FOOTING TO PROPOSED FINISHED GRADE. REFER TO TYPES AVAILABLE AND SELECT SIZE TO ASSURE TOP OF STAIRWELL WILL BE 2" TO 6" ABOVE FINISHED GRADE.

EXCAVATION REQUIRED

E. F. SHEA
NEW ENGLAND
CONCRETE PRODUCTS, INC.

BULKHEAD INSTALLATION
 RECOMMENDATIONS