



TOTAL SYSTEM CAPACITY: 1,300 GALLONS  
 RATED CAPACITY: 500-600 GALLONS PER DAY

NOTES:

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR ALTERNATE SEPTIC SYSTEMS
3. ALL REINFORCEMENT PER ASTM C1227-93.
4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.

**E.F. SHEA**  
 NEW ENGLAND  
 CONCRETE PRODUCTS, INC.

SINGULAIR® BIO-KINETIC®  
 WASTEWATER  
 TREATMENT SYSTEM  
 MODEL 960