



NOTES:

1. CONCRETE: 5,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR SEPTIC TANKS.
3. ALL REINFORCEMENT PER ASTM C1227-93.
4. DESIGNED FOR H-20 LOADING, COVER 1-5 FT.
5. TONGUE AND GROOVE JOINT SEALED WITH BUTYL RESIN. INLET HEIGHT MAY INCREASE SLIGHTLY DUE TO THE BUTYL RESIN USED.
6. TEES AND BAFFLES SOLD SEPARATELY.
7. SPANNERS USED IN CENTER SECTIONS FOR TANKS GREATER THAN 7000 GALLONS.

GALLONS	A (HEIGHT)	B (INLET)	C (LIQUID)	WEIGHT (LBS)	ITEM NO.
4,000	76"	58"	48"	53,100	TK-4000C
5,000	88"	70"	60"	56,990	TK-5000C
5,500	92"	74"	64"	58,180	TK-5500C
6,000	96"	78"	68"	59,460	TK-6000C
6,500	100"	82"	72"	60,840	TK-6500C
7,000	106"	88"	78"	62,640	TK-7000C
7,500	112"	94"	84"	64,590	TK-7500C
8,000	118"	100"	90"	66,510	TK-8000C
8,500	124"	106"	96"	68,450	TK-8500C
9,000	130"	112"	102"	70,370	TK-9000C
9,500	136"	118"	108"	72,290	TK-9500C
10,000	140"	122"	112"	73,580	TK-10000C
10,500	146"	128"	118"	75,500	TK-10500C
11,000	152"	134"	124"	77,430	TK-11000C
11,500	158"	140"	130"	79,360	TK-11500C
12,000	162"	144"	134"	80,640	TK-12000C

E. F. SHEA
NEW ENGLAND
CONCRETE PRODUCTS, INC.

COMMERCIAL LINE TANK
 4000 TO 12000 GALLON