



NOTES:

1. CONCRETE: 5,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR SEPTIC TANKS.
3. ALL REINFORCEMENT PER ASTM C1227-93.
4. BAFFLE WALL OPTIONAL FOR TWO COMPARTMENT TANKS.
5. DESIGNED FOR H-20 LOADING.
6. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
7. TEES AND BAFFLES SOLD SEPARATELY.

	WEIGHT
ITEM NO. CTK-2500	34,880#
CTK-25002C	37,470#

E.F. SHEA
NEW ENGLAND
CONCRETE PRODUCTS, INC.

COMMERCIAL LINE TANK
2500 GALLON
MONOLITHIC