



NOTES:

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
2. REINFORCED STEEL CONFORMS TO LATEST ASTM A185
3. BUTYL RESIN SECTION JOINT CONFORMS TO LATEST ASTM C443 SPEC

**E. F. SHEA**  
**NEW ENGLAND**  
**CONCRETE PRODUCTS, INC.**

PUMP STATION  
 DUPLEX PUMP PACKAGE  
 WITH "H" VALVE PIT